



Certificate No:
TAA000034G

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Programmable Controller

with type designation(s)
Nexto Xpress Series XP300, XP315, XP325, XP340

Issued to
ALTUS SISTEMAS DE AUTOMACAO S/A
São Leopoldo, Brazil

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Temperature	B
Humidity	B
Vibration	A
EMC	B
Enclosure	A

Issued at **Hamburg** on **2022-05-13**

for **DNV**

This Certificate is valid until **2027-05-12**.

DNV local station: **Station Rio de Janeiro, NB/CMC/Approval**

Approval Engineer: **Dariusz Lesniewski**

.....
Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 3

Product description

Programmable Logic Controller (PLC) Nexto Xpress Series

Controller Models:

Code	Description
XP300	High-Speed Compact PLC with 16 DI, 16 DO Transistor, 1 Ethernet, 1 RS-485 Serial and CANopen Master
XP315	High-Speed Compact PLC with 16 DI, 16 DO Transistor, 5 V/I AI, 2 RTD AI (3 wire), 1 Ethernet, 1 RS-485 Serial and CANopen Master
XP325	High-Speed Compact PLC with 16 DI, 16 DO Transistor, 5 V/I AI, 2 RTD AI (3 wire), 4 V/I AO, 1 Ethernet, 1 RS-485 Serial and CANopen Master
XP340	High-Speed Compact PLC with 16 DI, 16 DO Transistor, 5 V/I AI, 2 RTD AI (3 wire), 4 V/I AO, 1 Ethernet, 1 RS-485 Serial, CANopen Master and user web pages support

Power supply: 24V DC (min. 19.2 DC / max. 30V DC)
 (Filter TDK-Lambda model RSMN-2003 or equivalent to be used)

Mounting: DIN rail mount

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

Application/Limitation

- Installation in a separate metallic cabinet
- The 24 Vdc power supply port shall be equipped with a filter TDK-Lambda model RSMN-2003 or equivalent (reference document: data sheet TDK-Lambda RSMN series 2003, web211004)
- The cables of all ports (power, I/O and communication) shall be equipped with a pair of low/high frequency ferrites Wurth Electronics 74272221/74271221 or equivalent (reference documents: data sheets Wurth Electronics 74272221 Rev. 001.002, 74271221, Rev 008.000)
- User Manual Nexto Xpress MU216600 Rev. M, Chapter 3 (Installation) to be observed

Type Approval documentation

Data sheet: CE116100 Rev. L
 Data sheet: Wurth Electronics 74272221 Rev. 001.002, 74271221, Rev 008.000
 Data sheet: TDK-Lambda RSMN series 2003, web211004
 User Manual Nexto Xpress MU216600 Rev. M
 Test Report: TREO No. 463-32, issue 1 dated 2022-01-10
 Drawings: EE400668, EM016100, EM016101, EM016102, EM016103
 Software Release Notes Document, dated 23/12/2021
 Type approval Assessment Report issued at Rio de Janeiro on 2022-01-26

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE